

Notified body No.1121

Certificate of constancy of performance,
1121- CPR-AE5010

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Shuttle / Shuttle Bug / Shutta
Door Holders (Size 3 to 6)

Intended use:- For use on fire rated single leaf and double leaf doors
DOOR MOUNT PUSH SIDE APPLICATION.

Essential characteristics	Performance	Harmonised technical specification
	Test ref's : WIL 366703 & CFR 1607011.	
<u>Ability to release</u> 5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring 5.2.1 General 5.2.2 Electrical release requirements 5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.1.11 Temperature Rise 5.1.12 Damage 5.1.13 Fire / smoke doors	Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass NPD Pass NPD Pass Grade 1	EN 1155:1997+A1:2002/AC:2006
Essential characteristics	Performance	Harmonised technical specification
<u>Durability of Ability to release</u> 5.2.14.1 corrosion 5.2.14.2 corrosion	NPD	
<u>Dangerous Substances</u> <u>Annex ZA3</u>	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	EN 1155:1997+A1:2002/AC:2006

Certificate of constancy of performance,

1121-CPR-AE5010

produced by

Sonicco Ltd
Tinkers Croft, Beechwood Lane, Lewes.
East Sussex. BN7 3QG. United Kingdom

and produced in the manufacturing plant

J/065

This is coded form and the information is held by the Notified Body


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1155:1997+A1:2002/AC:2006

under system 1 of *AVCP* are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **23/09/16** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan
Certification Manager
Exova (UK) Limited trading as Warrington Certification,
Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK